

# Dolliver Municipal Water Supply 2025 Water Quality Report

This report contains important information regarding the water quality in the city water system. The source of the water is groundwater.

## City water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)		Compliance		Date	Violation	Source
			Type	Value & (Range)		Yes/No	
Copper (ppm)	AL=1.3	(1.3)	90th	0.0289 (0.002 - 0.042)	2024	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	AL=15	(0)	90th	ND (ND - <0.001)	2024	No	Corrosion of household plumbing systems; Erosion of natural deposits
<b>WATER TREATMENT PLANT</b>							
Combined Radium (pCi/L)	5	(0)	SGL	2.1	7/13/2021	No	Erosion of natural deposits
Sodium (ppm)	N/A	(N/A)	SGL	95.8	4/9/2024	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10	(10)	SGL	<0.1	4/8/2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Arsenic (ppb)	10	(0)	SGL	6.09	10/11/2023	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronic production wastes
Manganese (ppm)	HA 0.3 (ppm)		SGL	0.64 (0.58 - 0.67)	2025	No	Naturally occurring element found in soil, water, and air.

Note: Contaminates with dates indicate results from the most recent testing done in accordance with regulations.

## DEFINITIONS

**MCL (Maximum Contaminant Level)**-The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**MCLG (Maximum Contaminant Level Goal)**-The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**ppb**-parts per billion

**ppm**-parts per million

**pCi/L**-picocuries per liter

**N/A**-Not applicable

**ND**-Not detected

**RAA**-Running Annual Average

**TT (Treatment Technique)**-A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**AL (Action Level)**-The concentration of a contaminant which, if exceeded, triggers treatment or other requirements, which a water system must follow.

**MRDLG (Maximum Residual Disinfectant Level Goal)**-The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**MRDL (Maximum Residual Disinfectant Level)**-The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**SGL**-Single Sample Result

**RTCR**-Revised Total Coliform Rule

**NTU**- Nephelometric Turbidity Units

**Dolliver Municipal Water Supply is pleased to present to customers the quality water meets all current federal and state requirements.**

# 2025 Water Quality Report

**Dolliver Municipal Water Supply is pleased to present the Water Quality Report, designed to inform you about the quality of water you receive.**

**GENERAL INFORMATION** - Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Our water supply is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking and making baby formulas, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact DOLLIVER MUNI WATER SUPPLY at 712-262-8847. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Lead tap sampling data can be found in the Iowa Drinking Water Data Portal: <https://programs.iowadnr.gov/iowadrinkingwater>  
Our water supply has completed a service line inventory. Please contact us for information regarding the inventory and how you can access the results.

We sampled for Unregulated Contaminated Monitoring Rule 5 (UCMR5) as required by EPA. Any results above proposed MCL & MCLG are provided on this CCR.

## **ADDITIONAL HEALTH INFORMATION**

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Infants exposed to manganese over 0.3 mg/L may experience learning or behavioral problems. Adults drinking water with manganese levels greater than 1 mg/L for many years may experience impacts to their nervous system, resulting in behavioral changes and other nervous system effects, including slow and clumsy movements.

## **ADDITIONAL HEALTH INFORMATION**

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

## **SOURCE WATER ASSESSMENT INFORMATION**

This water supply obtains its water from the buried sand and gravel of the Buried Sand and Gravel aquifer. The Buried Sand and Gravel aquifer was determined to have low susceptibility to contamination because the characteristics of the aquifer and overlying materials provide natural protection from contaminants at the land surface. The Buried Sand and Gravel wells will have low susceptibility to surface contaminants such as leaking underground storage tanks, contaminant spills, and excess fertilizer application. A detailed evaluation of your source water was completed by the Iowa Department of Natural Resources, and is available from the Water Operator at 712-262-8847.

For questions regarding this information or how you can get involved in decisions regarding the water system, please contact the Dolliver Municipal Water Supply operations department at 712-262-8847.

Please contact Kelly Graplar with any questions at **Iowa Lakes Regional Water**

1301 38th Avenue West, Spencer, IA 51301

Phone: 712-262-8847 E-mail: [kelly.graplar@ilrw.org](mailto:kelly.graplar@ilrw.org)