

Iowa Lakes Regional Water 2025 Water Quality Report

This report contains important information regarding the water quality in our water system. The source of our water is groundwater.

Our water quality testing shows the following results:

| CONTAMINANT | MCL - (MCLG) | | Compliance | | Date | Violation | Source |
|--|-------------------------|-------|------------|------------------------|------------|-----------|---|
| | | | Type | Value & (Range) | | Yes/No | |
| 950 -DISTRIBUTION SYSTEM | | | | | | | |
| Copper (ppm) | AL=1.3 | (1.3) | 90th | 0.0285 (0.002 - 0.045) | 2023 | No | Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives |
| Lead (ppb) | AL=15 | (0) | 90th | ND (ND - 0.40) | 2023 | No | Corrosion of household plumbing systems; Erosion of natural deposits |
| Total Trihalomethanes (ppb) [TTHM] | 80 | (N/A) | LRAA | 20.1 (20.1 - 20.1) | 7/1/2025 | No | By-products of drinking water chlorination |
| Total Haloacetic Acids (ppb) [HAA5] | 60 | (N/A) | LRAA | 12.2 (12.2 - 12.2) | 7/1/2025 | No | By-products of drinking water disinfection |
| Chlorine (ppm) | MRDL=4.0 (MRDLG=4.0) | | RAA | 1.41 (0.72 - 1.83) | 12/31/2025 | No | Water additive used to control microbes |
| 01 - Wells 1, 4-11 - CLAY WATER TREATMENT PLANT TAP | | | | | | | |
| Fluoride (ppm) | 4 | (4) | RAA | 0.54 (0.48 - 0.61) | 2025 | No | Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories |
| Barium (ppm) | 2 | (2) | SGL | 0.0218 | 4/12/2022 | No | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits |
| Sodium (ppm) | N/A | (N/A) | SGL | 4.75 | 4/16/2025 | No | Erosion of natural deposits; Added to water during treatment process |
| Manganese (ppm) | HA 0.3 (ppm) | | SGL | <0.01 | 10/27/2025 | No | Naturally occurring element found in soil, water, and air. |
| Nitrate [as N] (ppm) | 10 | (10) | SGL | 0.138 | 4/16/2025 | No | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits |

Note: Contaminates with dates indicate results from the most recent testing done in accordance with regulations.

Iowa Lakes Regional Water is pleased to present to our customers quality water that meets and exceeds all federal and state requirements.

DEFINITIONS

MCL (Maximum Contaminant Level)-The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal)-The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

ppb-parts per billion

ppm-parts per million

pCi/L-picocuries per liter

N/A-Not applicable

ND-Not detected

RAA-Running Annual Average

NTU- Nephelometric Turbidity Units

TT (Treatment Technique)-A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

AL (Action Level)-The concentration of a contaminant which, if exceeded, triggers treatment or other requirements, which a water system must follow.

MRDLG (Maximum Residual Disinfectant Level Goal)-The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MRDL (Maximum Residual Disinfectant Level)-The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

SGL-Single Sample Result **NTU**- Nephelometric Turbidity Units

RTCR-Revised Total Coliform Rule

2025 Water Quality Report

Iowa Lakes Regional Water is pleased to present the Water Quality Report, designed to inform you about the quality of water and services we deliver.

GENERAL INFORMATION - Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Our water supply is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly.. Use only cold water for drinking, cooking and making baby formulas, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact IOWA LAKES REGIONAL WATER at 712-262-8847. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Lead tap sampling data can be found in the Iowa Drinking Water Data Portal: <https://programs.iowadnr.gov/iowadrinkingwater>

Our water supply has completed a service line inventory. Please contact us for information regarding the inventory and how you can access the results.

SOURCE WATER ASSESSMENT INFORMATION

This water supply obtains its water from the sand and gravel of the Alluvial aquifer. The Alluvial aquifer was determined to be highly susceptible to contamination because the characteristics of the aquifer and overlying materials provide little protection from contamination at the land surface. The Alluvial wells will be highly susceptible to surface contaminants such as leaking underground storage tanks, contaminant spills, and excess fertilizer application. However, the source wells are monitored with a source water protection plan, utilizing the Iowa DNR wildlife and nature prairie areas, and a CRP well head protection plan - all to mitigate spills and prohibiting any fertilizer application from entering the ILRW production capture zone. A detailed evaluation of your source water was completed by the Iowa Department of Natural Resources, and is available from the Water Operator at 712-262-8847.

Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect your water resources. We are committed to ensuring the quality of your water.

QUESTIONS: Please contact Kelly Graplar
Iowa Lakes Regional Water
1301 38th Avenue West
Spencer, IA 51301
Phone: 712-262-8847
E-mail: kelly.graplar@ilrw.org